

EMERGENCY STOPS

If the design of plant at a workplace includes an emergency stop control, the person with management or control of the plant **must** ensure that:

- the stop control is prominent, clearly, and durably marked and immediately accessible to each operator of the plant
- any handle, bar or push button associated with the stop control is coloured red, and
- the stop control cannot be adversely affected by electrical or electronic circuit malfunction.

Where the plant is designed to be operated or attended by more than one person and more than one emergency stop control is fitted, the person with management or control of the plant must ensure that the multiple controls are of the ‘stop and lock-off’ type so that the plant cannot be restarted after an emergency stop control has been used unless each activated stop control is reset.



For more information relating to Emergency E Stops refer to Emergency stops WHS Regulation 211